

TORONTO MUNICIPAL CODE  
CHAPTER 851, WATER SUPPLY

**SCHEDULE 6 TO CHAPTER 851  
AUTHORIZED FUNCTIONS LIST**

[Amended 2008-12-03 by By-law No. 1250-2008; 2010-07-08 by By-law No. 869-2010; 2013-12-18 by By-law No. 1697-2013]

Item	Function	Professional Engineer with CCCS Certification	Certified Engineering Technologist with CCCS Certification *	Licensed Master Plumber with a City of Toronto plumbing contractor's licence and CCCS Certification	Journeyman Plumber with CCCS Certification †	Apprentice plumber with CCCS Certification ‡	Fire system sprinkler fitter with CCCS Certification	Industrial Millwright with CCCS Certification
1	Carry out cross-connection / backflow prevention device survey	√	√	√	√			
2	Install, relocate, or replace backflow prevention device			√	√	√		
3	Repair backflow prevention device	√	√	√	√	√		
4	Test backflow prevention device	√	√	√	√	√	√	√
5	Complete Items 1, 2, 3 and 4 in relation to fire protection systems	√	√	√	√	√	√	

√	<i>Authorized to perform function</i>
*	<i>Required to be under the direction of a Professional Engineer</i>
†	<i>Required to be employed by a City of Toronto licensed plumbing contractor</i>
‡	<i>required to be employed by a licensed plumbing contractor and under the direct supervision of a journeyman <b>with CCCS Certification</b> or master plumber <b>with CCCS Certification</b></i>
Note:	<b><i>if a plumber or a Industrial Millwright is employed by an organization or institution for whom the work is performed, then a City of Toronto plumbing contractor licence is not required.</i></b>
CCCS	Cross Connection Control Specialist <b>Note: Please refer to § 851-8F for the criteria for acceptable CCCS</b>